

8.2 Laser Altimeter

Apollo 17
pan camera
Calibration
2/28/57

APOLLO 17

LASER ALTIMETER CALIBRATION DATA

MAPPER CAMERA NO. 71-004

LENS NO. 203


ALTIMETER NO. 0006

LASER ALTIMETER GROUND MEASUREMENT POINT

The positions of all points are referenced to the Indicated Principal (IPP) as origin with the straight line drawn between the A and B points being coincident with the X-axis. The CD line goes through the origin but is not generally coincident with the Y-axis.

1 Box = 0.001 mm

Emulsion Down



⊕ X_{LAGP} = -0.008 mm

⊖ X_{LAGP} = -0.008 mm

AVG X_{LAGP} = -0.008 mm

⊕ Y_{LAGP} = -0.006 mm

⊖ Y_{LAGP} = -0.006 mm

AVG Y_{LAGP} = -0.006 mm

NOTE: SIGNS ARE CORRECT FOR EMULSION DOWN MEASUREMENT.

[Handwritten Signature]
11-4-72

X_{LAGP} - Location on X - coordinate of Laser Altimeter Ground Measurement Point

Y_{LAGP} - Location on Y - coordinate of Laser Altimeter Ground Measurement Point

⊕ - "+g" mode

⊖ - "-g" mode

8.3 Optical Bar Panoramic Camera

APOLLO 17

PANORAMIC CAMERA CALIBRATION DATA

APOLLO 17
TEST PROCEDURE

FOR
PROJECT 9446
VEILING GLARE MEASUREMENTS
PANORAMIC CAMERA
FOR SCIENTIFIC INSTRUMENT
MODULE
EXPERIMENT S-163



ITEK CORPORATION
Lexington 73, Massachusetts

Date 9-15-70

	PREPARED	PROJECT APPROVAL	QUALITY ASSURANCE APPROVAL
By	R. SHERLOCK	C. BACKE	R. WESPISER
Signed	<i>R. Sherlock</i>	<i>C. Backe</i>	<i>R. Wespiser</i>
Date	<i>9/17/70</i>	<i>9/21/70</i>	<i>9/18/70</i>

CUST./GOV'T. REP. _____ Date _____
Reviewed

6.3.1.3 Itek Test Data Sheet

VEILING GLARE MEASUREMENT

Panoramic Camera Lens, P/N 105150, Serial No. M-53

Step No.	Step Wedge							Black Dot	% Veiling Glare
	1	2	3	4	5	6	7	X	
* Calibrated Value									
	1.22	1.07	.92	.78	.65	.50	.36	X	
* Measured Test Values									
-6°	.18	.26	.38	.58	.79	1.14	1.58	.46	13.8
-4°	.20	.28	.42	.66	.92	1.24	1.58	.51	13.8
-2°	.20	.27	.42	.66	.92	1.24	1.58	.50	13.3
0°	.20	.26	.37	.58	.82	1.10	1.45	.46	14.1
+2°	.20	.25	.36	.57	.86	1.08	1.49	.64	17.8
+4°	.20	.28	.44	.71	.88	1.36	1.57	.70	16.2
+6°	.22	.30	.46	.70	.99	1.27	1.58	.78	17.9

Legend: * Density values are logarithmic as read on the Macbeth Densitometer.

% Veiling Glare is computed from the black spot density plot (attached) for each field position.

Data Recorded By: S. L. Hill Date: 9/23/70

QA Monitor: H. R. McBride 9-25-70

Project Approval: [Signature] 9-25-70

Test Procedure No. TP121

Page 8

9

TEST PROCEDURE

FOR

PROJECT 9446
 SPECTRAL TRANSMITTANCE
 MEASUREMENTS
 PANORAMIC CAMERA
 FOR SCIENTIFIC INSTRUMENT
 MODULE

EXPERIMENT S-163



ITEK CORPORATION

Lexington 73, Massachusetts

Date 9-15-70

	PREPARED	PROJECT APPROVAL	QUALITY ASSURANCE APPROVAL
By	R. SHERLOCK	C. BACKE	R. WESPISER
Signed	<i>R. Sherlock</i>	<i>C. Backe</i>	<i>R. Wespiser</i>
Date	<i>9/17/70</i>	<i>9/21/70</i>	<i>9/17/70</i>

CUST./GOV'T. REP. _____ Date _____
 Reviewed _____

6.3.1.3 Itek Test Data Sheet

SPECTRAL TRANSMITTANCE MEASUREMENT

Panoramic Camera Lens, P/N 105150, Serial No. N-53

Wavelength nm	Radiometer Readings				% Transmittance
	A	A ₁	B	B ₁	
400	5.7	2.0	1.2	.2	47.5
420	18.3	6.7	3.4	.6	48.2
440	35.5	13.5	6.3	1.3	54.3
480	83.0	33.0	15.0	3.9	65.4
520	128.0	52.0	23.3	6.8	71.8
560	143.0	58.0	26.0	7.6	72.1
601	133.0	53.0	23.7	6.5	68.8
640	118.0	43.0	20.7	4.8	63.6
680	97.5	34.5	17.3	3.4	55.5
720	51.5	23.5	12.7	2.1	32.2

Legend:

- A = Brightness of the calibrated standards Lambertian source using the radiometer telescope.
- A₁ = Brightness of the collimator target as seen from the lens test position using the radiometer telescope.
- B = Brightness of the calibrated standard Lambertian source using the radiometer microscope.
- B₁ = Brightness of the collimator target aerial image at the image plane (lens in place) using the radiometer microscope.

% Transmittance = $\left[\frac{B_1}{B} \div \left(\frac{A_1}{A} \right) \right] \times 100$.

Data Recorded By: S. J. Stahl Date: 9/23/70
 QA Monitor: H. R. Mc Brial 9-25-70
 Project Approval: D. O. [Signature] 9/25/70

Test Procedure No. TP123

Q199-5 11/65

ITEK CORPORATION
Lexington 73, Massachusetts

2

6.3.1.3 Itek Test Data Sheet

T STOP CALCULATION

Panoramic Camera Lens, P/N 105150, Serial No. N-53

Wavelength nm	% Transmittance	T STOP
400	47.5	5.08
420	48.2	5.04
440	54.3	4.81
480	65.4	4.33
520	71.8	4.14
560	72.1	4.12
601	68.8	4.22
640	63.6	4.39
680	55.5	4.69
720	36.2	5.83

Legend:

$$T \text{ STOP} = \frac{f/\text{number}}{\sqrt{t}}$$

where f/number is 3.5 and
t is transmittance.

Data Recorded By: J. H. StolkDate: 9/25/70QA Monitor: H. R. Mc Bride9-25-70Project Approval: D. J. Dixon9/25/70Test Procedure No. TP123Page 9

Q199-5 11/65

ITEK CORPORATION
Lexington 73, Massachusetts

25

Test Procedure No. TP127

No. of Pages 5

TEST PROCEDURE

FOR

PROJECT 9446
C.F.L./MEASUREMENTS
PANORAMIC CAMERA
FOR SCIENTIFIC INSTRUMENT
MODULE
EXPERIMENT S-163



ITEK CORPORATION
Lexington 73, Massachusetts

Date 9-15-70

	PREPARED	PROJECT APPROVAL	QUALITY ASSURANCE APPROVAL
By	R. SHEPLOCK	C. BACKE	R. WESPISER
Signed	<i>[Signature]</i>	<i>[Signature]</i>	<i>[Signature]</i>
Date	<u>9/17/70</u>	<u>9/21/70</u>	<u>9/21/70</u>

CUST./GOV'T. REP. _____ Date _____
Reviewed _____


Lens N- 53

C.F.L. Calibration Summary

Filter	Field Position (degrees)	Mean C.F. L. (inches)	STD Deviation of mean CFL (inches)
23A	+6	23.9991	0.0002
	+4	24.0002	0.0007
	+2	24.0026	0.0009
	0 *	24.0008	0.0005
	-2	24.0008	0.0010
	-4	24.0018	0.0003
	-6	24.0003	0.0003
12	+6	24.0030	0.0012
	+4	24.0053	0.0010
	+2	24.0045	0.0019
	0 *	24.0029	0.0007
	-2	24.0009	0.0014
	-4	24.0028	0.0009
	-6	24.0009	0.0006
8	+6	24.0040	0.0002
	+4	24.0070	0.0008
	+2	24.0069	0.0003
	0 *	24.0052	0.0006
	-2	24.0048	0.0016
	-4	24.0045	0.0004
	-6	24.0041	0.0012
2A	+6	24.0033	0.0003
	+4	24.0059	0.0004
	+2	24.0056	0.0008
	0 *	24.0040	0.0006
	-2	24.0030	0.0007
	-4	24.0036	0.0002
	-6	24.0023	0.0008
no filter	+6	24.0036	0.0004
	+4	24.0052	0.0008
	+2	24.0067	0.0015
	0 *	24.0031	0.0010
	-2	23.9998	0.0010
	-4	24.0023	0.0007
	-6	24.0011	< 0.0001

* Average of all field positions

Quality Assurance Review



5.3.1.3 Itek Test Data Sheet


RELATIVE ILLUMINATION MEASUREMENT

Panoramic Camera Lens, P/N 105150, Serial No. 11-53

	Field Position	Radiometer Readings vdc	Relative Illumination %
B	-6°	66	90.4
	-5°	70	95.9
	-4°	71	97.3
	-3°	72	98.6
	-2°	72	98.6
	-1°	72.5	99.3
A	0°	73	100.0
B	+1°	72.5	99.3
	+2°	71.5	97.9
	+3°	71.5	97.9
	+4°	71	97.3
	+5°	69.5	95.2
	+6°	66.5	91.1

Meter Scale for Radiometer Readings: 1K

% Relative Illumination = $\frac{B}{A} \times 100$



Data Recorded By: J. F. [Signature] Date: 9/23/70
 QA Monitor: H. R. [Signature] 9-25-70
 Project Approval: [Signature] 9-25-70

Test Procedure No. TP125

3.5

Test Procedure No. TP127

No. of Pages 5

TEST PROCEDURE

FOR

PROJECT 9446
 C.F.L./MEASUREMENTS
 PANORAMIC CAMERA
 FOR SCIENTIFIC INSTRUMENT
 MODULE
 EXPERIMENT S-163



ITEK CORPORATION
 Lexington 73, Massachusetts

Date 9-15-70

	PREPARED	PROJECT APPROVAL	QUALITY ASSURANCE APPROVAL
By	R. SHERLOCK	C. BACKE	R. WESPISER
Signed	<i>[Signature]</i>	<i>[Signature]</i>	<i>[Signature]</i>
Date	<u>9/17/70</u>	<u>9/21/70</u>	<u>9/21/70</u>

CUST./GOV'T. REP. _____ Date _____
 Reviewed _____

Lens N- 53

C.F.L. Calibration Summary

Filter	Field Position (degrees)	Mean C.F. L. (inches)	STD Deviation of mean CFL (inches)
23A	+6	23.9991	0.0002
	+4	24.0002	0.0007
	+2	24.0026	0.0009
	0 *	24.0008	0.0005
	-2	24.0008	0.0010
	-4	24.0018	0.0003
	-6	24.0003	0.0003
12	+6	24.0030	0.0012
	+4	24.0053	0.0010
	+2	24.0045	0.0019
	0 *	24.0029	0.0007
	-2	24.0009	0.0014
	-4	24.0028	0.0009
	-6	24.0009	0.0006
8	+6	24.0040	0.0002
	+4	24.0070	0.0008
	+2	24.0069	0.0003
	0 *	24.0052	0.0006
	-2	24.0048	0.0016
	-4	24.0045	0.0004
	-6	24.0041	0.0012
2A	+6	24.0033	0.0003
	+4	24.0059	0.0004
	+2	24.0056	0.0008
	0 *	24.0040	0.0006
	-2	24.0030	0.0007
	-4	24.0036	0.0002
	-6	24.0023	0.0008
no filter	+6	24.0036	0.0004
	+4	24.0052	0.0008
	+2	24.0067	0.0015
	0 *	24.0031	0.0010
	-2	23.9998	0.0010
	-4	24.0023	0.0007
	-6	24.0011	< 0.0001

* Average of all field positions

Quality Assurance Review

H R Mc Brien

40